

**IEC****IECEE**

®

TM

Ref. Certif. No.

CN55202

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

SWITCH DISCONNECTOR FUSE

Name and address of the applicant

SOCOMECS.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMECS.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

SOCOMECS.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Note: When more than one factory, please report on page 2

 Additional information on page 2

Ratings and principal characteristics

Uimp: 8kV;Ui: 800V;Ith:315A(FUSERBLOC315A),400A(FUSERBLOC400A);  
Ue:AC690V;Ie:AC-22B-400A(FUSERBLOC400A),AC-23A-315A(FUSERBLOC315A); Utilization  
category: AC-22B,AC-23A; Number of poles:2P,3P,4P,3P+Additionalneutral pole(3 protected poles with an  
uninterrupted neutral pole); Iq:50kA,Rated frequency:50/60Hz

Trademark / Brand (if any)

SOCOMECS

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

FUSERBLOC315A,FUSERBLOC400A;

Additional information (if necessary may also be reported on page 2)

IEC 60947-1:2020;IEC 60947-3:2020

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-099777

This CB Test Certificate is issued by the National Certification Body

**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Nov.09,2021

Signature:

谢肇旭

Xie ZhaoXu

CB 0065330





® TM

Ref. Certif. No.

CN55202

Name of the factory	Address of the factory
1.SOCIETE TIMELEC SARL	ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA NAASSEN 1135 NAASSEN GOUVERNORATDE BEN AROUS, Tunisia

Additional information (if necessary)

Date: Nov.09,2021

Signature:



Xie ZhaoXu