

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2019010302217619

Valid from: Sep.21,2020

Valid until: Jul.20,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT SOCOMEC S.A
1, Rue De Westhouse 67230 Benfeld Cedex France

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER SOCOMEC S.A
1, Rue De Westhouse 67230 Benfeld Cedex France

NAME AND LOCATION OF THE FACTORY Sontheimer Electroschaltgeraete GmbH
Wendelsteiner Strasse 5,91126,Schwabach,Germany

PRODUCT NAME, MODEL AND SPECIFICATION Switch disconnecter
COMO 32A,COMO 63A; Uimp:6kV; Ui:690V; Ith: 32A(COMO 32A), 63A(COMO 63A); COMO 32A:AC-23A:Ue/Ie:AC400V/22A,AC690V/13A; AC-3:Ue/Ie:AC400V/20A,AC690V/11.5A; COMO 63A:AC-23A:Ue/Ie:AC400V/41A,AC690V/21A; AC-3:Ue/Ie:AC400V/35A,AC690V/17A; Iq:8kA; Utilization Category : AC-23A, AC-3; Poles : 3P,3P+N; Attached Auxiliary Contacts: 1NO+1NC; Ith:10A;Ui:690V; AC-15:Ue/Ie:AC120V/6A,AC230V/3A,AC500V/1.4A; DC-13:Ue/Ie:DC125V/1.1A,DC250V/0.3A;

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T14048.3-2017

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

SIGNATURE



CHINA QUALITY CERTIFICATION CENTRE